

# Certificate of Compliance

**Certificate Number:**

R41092

**Report Reference:**

R41092-2023-12-14

**Issue Date:**

2025-10-29

Issued to:

**EFS Engineering Ltd.**

**393 Harishonim St, Ein Vered, 40696, Israel |**

This certificate confirms that representative samples of:

**Fire-protective Curtains**

**See Addendum Page for Product Designation(s).**

Has been evaluated by UL LLC in accordance with Standard(s) for Safety:

**UL 10D, Fire Tests of Fire-Protective Curtain Assemblies, Edition 2**

**UL 1784, Air Leakage Tests of Door Assemblies and Other Opening Protectives, Edition 4.**

**NFPA 105, Standard for Smoke Door Assemblies and Other Opening Protectives.**

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch  
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



# Certificate of Compliance

**Certificate Number:** R41092  
**Report Reference:** R41092-2023-12-14  
**Issue Date:** 2025-10-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model **EFS-FC, Single Barrel**, Fire-Protective Curtains, surface or between-jamb mounted, rated up to and including 2 hr., also rated for air leakage assemblies, for use in masonry wall type constructions for openings not exceeding **9000 mm (354.33 in)** in width and 12000 mm (472.44 in) in height. Products larger than 4200mm high by 5990mm wide are considered to be oversized fire-protective curtains.

Model **EFS-FC, Multi-barrel**, Fire-Protective Curtains, surface or between-jamb mounted, rated up to and including 3 hr., for use in masonry wall type constructions for openings not exceeding 300 m (11811.03 in) in width and 12000 mm (472.22 in) in height.